

試驗報告



報告編號：HV-19-05423

頁數：1 OF 3

報告日期：2019年10月15日

白馬窯業股份有限公司
桃園市楊梅區新榮里電研路5號

產品名稱：白馬SPC環保防水地板
供應廠商：白馬窯業股份有限公司
送驗廠商：白馬窯業股份有限公司
收件日期：2019年09月16日
試驗日期：2019年09月16日~2019年10月15日
備註：1.以上資料由顧客提供(收件及試驗日期除外)
2.除非另有說明，此報告結果僅對測試之樣品負責
未經本公司事先書面同意，此報告不可部分複製
3.下述報告內容標示#處由顧客提供
4.本樣品由SGS材料暨工程實驗室-中壢(申請書號碼：LV-19-00335，
收件日期：2019年09月16日)轉送至本實驗室執行本報告所示之試驗項目。

=====

本實驗室依據顧客所提供之試驗需求與樣品進行試驗，結果說明如下：

試驗需求：防滑性試驗

試驗方法：請參見附頁

試驗結果：請參見附頁

報告簽署人

本報告若有提供規範值，該規範值僅供參考，合格之判定以委託單位實際要求為準

試驗報告



報告編號：HV-19-05423

頁數：2 OF 3

報告日期：2019年10月15日

防滑性試驗

試驗方法：

CNS 8907(2016)

建築用聚合物地磚試驗法

試驗結果：

試驗項目		試驗結果		
		樣品 1	樣品 2	樣品 3
防滑性試驗	表面狀態	清掃及乾燥狀態		
	測試環境溫度(°C)	24.6		
	C.S.R (防滑係數)	0.71	0.69	0.69

註：滑動片選用硬度 72~80，厚度 3~6 mm 的橡膠片。

本報告若有提供規範值，該規範值僅供參考，合格之判定以委託單位實際要求為準

試驗報告




報告編號：HV-19-05423

頁數：3 OF 3

報告日期：2019年10月15日

樣品照片：



試驗樣品

----- o O o -----

本報告若有提供規範值, 該規範值僅供參考, 合格之判定以委託單位實際要求為準

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.