

試驗報告

報告編號: TB-20-00423

C-20-01180

數:1 OF 1

報告日期:109年02月06日

工程名稱: 自測 包 商: ---

委 託 單 位: 白馬窯業股份有限公司

地 址: 桃園市楊梅區新榮里電研路5號

供 料 廠 商: ---

樣 品 名 稱: 白馬複合木質地板

送 驗 人 員: 白馬窯業股份有限公司-白永泰

收件日期:109年01月22日

試 驗 日 期: 109年02月03日~109年02月06日

註: 1.以上資料由顧客提供(收件及試驗日期除外)

2.除非另有說明,此報告結果僅對測試之樣品負責 未經本公司事先書面同意,此報告不可部分複製

3.送樣方式為實驗室收件

試 驗 方 法: CNS 3299-12(2011)陶瓷面磚試驗法-第12部:防滑性試驗法

試驗結果:

試體編號 —	防滑性試驗結果		
	1	2	3
表面狀態	使用自來水做為媒介物,散佈量約400g/m ²		
測試環境溫度(℃)	24.3		
最大值	0.757	0.794	0.800
最小值	0.744	0.776	0.788
C.S.R值穿鞋時之防滑係數	0.75	0.78	0.80

試體編號	防滑性試驗結果			
6八、月豆、5种 2/元	1	2	3	
表面狀態	使用滑石粉加入約300倍質量之自來水混合成懸濁液 做為媒介物,散佈量約100g/m²			
測試環境溫度(℃)	24.3			
最小值	0.879	0.924	0.888	
C.S.R B值赤腳時之防滑係數	0.89	0.93	0.89	

註:1、本試驗樣品不在認可範圍內(非規範描述之材料),故無法出具TAF標誌報告。

2、委託單位送樣規格200×200×7.7 mm。

3、本試驗報告之試驗地點同實驗室地址。

----- oOo -----

本報告若有提供規範值時,該規範值僅供參考,合格之判定以委託單位實際要求為準

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <a href="http://www.sgs.com/en/Terms-and-Conditions/Terms-an

TWC 8629818